



The Effects of Environmental and Renewable Energy Policies on the Existence Conditions for Distributed Generators in Electricity Markets.

Zaida Contreras

8th June, 2010

PhD student • School of Economics


www.ceem.unsw.edu.au

© CEEM, 2010



Background

- Electric power source which is connected directly to the distribution network or on the customer site of the meter (Ackermann, 2001).



Benefits of decentralised generation

- Structural benefits: avoided transmission costs, supply reliability (Gulli, 2006), (Firestone et al., 2006).
- In constrained areas: Avoided/deferred investment in capacity extension (Woo et al., 1995). Reduction of grid congestion (Firestone et al., 2006).
- CHP: lower-cost, higher efficiency, lower carbon footprint (Siddiqui, 2008).
- Decentralisation: transferring power and resources (Alanne, 2006). More direct decision making in planning, use of technologies (Winner, 1986).

Motivation

- Distributed Generation (DG) presents a number of benefits that support a more rational electricity supply in face of increasing market requirements in relation to demand growth and environmental degradation.
- **Existing models in relation to DG present :**
 - Economic feasibility in terms of project management
 - Case studies: specific sites and choice of technologies
 - ESM (CSIRO): diffusion of DG at the macro level (top-down)
 - Based on simulations of energy systems, operations research: requires good data, extense set of assumptions.

There is insufficient literature using economic models with focus on the adequacy of policy instruments in the field of distributed generation.


Research Scope

Identify requirements for the existence of Distributed Generation

Australian context: ETS for carbon (postponed), state-based local pollution control measures (e.g. Load based Licensing in NSW), national markets for REC are in place to enhance generation from renewable energy (RE target: 45 TWh by 2020).


Research Questions

- What are the effects of taxing local pollution and greenhouse gases, together with subsidising electricity from renewable sources **on electricity prices?**
- What are the subsequent effects on the **market share of locally generated electricity?**
- What is the impact of taxes and the RET scheme **on the DG-mix** that is feasible in the current state of technology?



Theoretical Model

- Analysis: conditions in equilibrium for DG to exist embedded in the electricity network following the dominant firm price leadership model.
 - DG cost minimisation problem
 - Grid network provider's profit maximisation
- Simulation associated with different technologies
 - Mix of existing DG options (natural gas, biomass, wind, solar)



5

Theoretical Model

- 1) Grid Provider: act as a monopoly

$$\max_{y^g} \Pi^g = P(y^g, \bar{y}^{DG}) y^g - C(y^g, x_E^g, x_P^g) \quad \text{subject to} \quad \begin{cases} x_E^g = \gamma_E^g y^g \\ x_P^g = \gamma_P^g y^g \end{cases}$$

- 2) Distributed Generators: competitive fringe, price takers

$$\min_{x_K^{DG}, x_L^{DG}, x_F^{DG}} C(y^{DG}) = C(\bar{x}^{DG}, \bar{w}^{DG}) - (1 - \gamma^{DG})^n \bar{p}_{rec} y^{DG} \quad \text{subject to} \quad y^{DG} = f^{DG}(\bar{x}^{DG})$$

- 3) Market Clearing Condition: $y^g(p) + y^{DG}(p) = z(p)$


Assumptions

- The dominant firm knows the market's demand curve and the competitive fringe's supply curve.
- There is a common market for electricity, but only the centralised generator is liable for the associated emissions. Small DG firms do not affect prices of their input factors or any upstream market.
- Cost function: convex with $C(0)=0$, $C_y' > 0$, $C_y'' > 0$ (weakly convex for DG).
- DG firms exhibit constant returns of scale, but there is a capacity constraint.
- There is no market entry

6

Market interaction

- Equilibrium conditions for the interior solution: simultaneous generation from grid and DG



Findings

- There exists an equilibrium price p^* solving the grid provider's profit maximisation problem such that $p^* \geq mc^{DG}$.

Assuming

a linear market demand, $p = a - by$

a cost function for grid provider $C(y^g) = k\frac{y^g{}^2}{2} + \gamma_E^g \tau_E y^g + \gamma_P^g \tau_P y^g$

and a cost function for DG $C(y^{DG}) = \begin{cases} MC^{DG}(\vec{w}) y^{DG} - (1 - \gamma^{DG})^n \bar{p}_{rec} & y^{DG} \leq \bar{Y}_{max}^{DG} \\ \infty & y^{DG} > \bar{Y}_{max}^{DG} \end{cases}$

- It was found that the equilibrium condition is characterised by:
 - high marginal costs of the grid network
 - large market size
 - high willingness to pay for electricity

Findings

- In the interior solution: if the market demand is fixed, augmenting the capacity of distributed generation will decrease the equilibrium price of electricity.
- Given a market with the characteristics mentioned previously and in the presence of DG, the grid provider will maximise its profits by setting the electricity price p^* that simultaneously will create profits for the industry of the smaller firms:



Equilibrium electricity price:
$$p^* = \frac{MC(y^g) + \gamma_E^g \tau_E + \gamma_P^g \tau_P}{\frac{1}{\eta} \cdot \frac{y^g}{z} + 1}$$

↑ environmental taxes, ↑ electricity prices, ↓ grid's output, which ↑ DG


Findings

- Effect of environmental and renewable energy policies:
 - Taxes on carbon emissions or pollution: Increase electricity price and share of DG along with their mark up. Minimum tax levels for DG into the market:

$$\tau_P \geq \frac{MC^{DG}(\frac{1}{\eta}+1) - MC^g(y^g)}{\gamma_P^g}$$

$$\tau_E \geq \frac{MC^{DG}(\frac{1}{\eta}+1) - MC^g(y^g)}{\gamma_E^g}$$

- Subsidy to renewable generation: Electricity prices and share of DG remain unchanged.
- Combining both policies: electricity prices increase according to emission factors of the dominant firm, which allows DG firms to increase their share and market profit.



Conclusion

- Local generation embedded in the electricity grid network can be adequately modelled with the price-dominant leadership model.
- A market with high willingness to pay, large size and relatively high marginal costs of the grid provider are required to obtain simultaneous participation of the dominant firm and the DG fringe.
- Environmental taxes are set to internalise the effect of pollution and carbon emissions of centralised generation. However, at a certain level they can also support the integration of small scale DG.
- Renewable energy subsidies reduce the marginal costs of DG firms, but in the short run does affect electricity prices.
- Future work: complete numerical simulations to account for heterogeneity among DG technologies.
Extension for market entry following DG's positive profit.

Acknowledgements

- Advice on theory: A/Prof. Arghya Ghosh (UNSW)
- Supervisors: Professor Denzil Fiebig (School of Economics, UNSW), Dr. Regina Betz (School of Economics and CEEM, UNSW)
- Preliminary reviews from: Johanna Reichenbach (University of Kiel) and Christoph Heinzl (University of Toulouse).

Thank you!