

Experiences with Residential Grid-Connected PV Systems in Australia

Dr Muriel Watt - SPREE UNSW
 Dr Rhys Morgan BP Solar
 Dr Robert Passey CEEM UNSW

m.watt@unsw.edu.au
 rhys.morgan@bp.com



UNSW ENGINEERING

ANZSES 2006



Contents

- 1. Introduction
- 2. Grid Connected PV Installations in Australia
 - The PV Rebate Program
 - System Cost Trends
- 3. Experiences with Residential PV Systems in NSW
 - Analysis of a 1.6 kW System
 - System performance
 - 1000 systems in Newington
 - Newington PV Performance
- 4. PV Performance and Issues Raised
 - Conflicting expectations and objectives
 - System performance and customer expectations
- 5. Conclusions and Recommendations

UNSW ENGINEERING

ANZSES 2006




Introduction

- Over 6 MW of grid-connected PV in Australia connected to date.
- Majority domestic homes direct purchase or pre installed e.g. Newington
- Boom in Europe, Japan USA -> silicon shortage, causing problems with supply and price.
- Australia - market moderate growth, driven by PVRP & Green Power

UNSW ENGINEERING

ANZSES 2006



System Cost Trends


- Data from BP Solar's Envirocashback – manufacturers' database
- Analysis shows end user cost has decreased since 2003 by 8%
- Average system cost \$/W per watt has decreased from \$13.05 in 2003 to \$11.89 in 2005, despite PV module price rises
- So - reductions in BOS, installation, standardisation?
- Domestic electricity tariffs increased by 15% for the household monitored here since PV installed, and are expected to continue to increase at 5% per year above CPI

UNSW } ENGINEERING


ANZSES 2006



Envirocash Back Trends



Analysis of a 1.6 kW System



- Energy delivered in 2005 was 2426kWh, 1515kWh/kWp, 1571kWh/kWp
- Compares well with ORER 1382kWh/kWp and 1376kWh design prediction
- Avg daily energy 6.65kWh, 10.28kWh max (6.4 PSH)

UNSW } ENGINEERING

ANZSES 2006



Daily energy statistics

Month	Sum	Ave'	Max'	Min'	Std Dev
1	251.81	8.12	10.3	2.49	1.83
2	216.86	7.74	9.37	3.96	1.51
3	221.99	7.16	9.47	1.21	2.17
4	208.36	6.95	8.62	2.80	1.44
5	186.18	6.01	7.36	2.19	1.37
6	114.11	3.80	6.91	0.05	2.32
7	148.88	4.80	7.33	0.51	2.42
8	197.18	6.36	8.42	1.37	2.16
9	206.97	6.90	9.35	0.92	2.24
10	201.72	6.51	9.30	1.30	2.60
11	211.53	7.05	9.74	2.29	2.23
12	261.20	8.43	9.49	4.39	1.16
-	2426	6.65	10.28	0.05	-

Energy delivered over 2005


- Energy = power & time
- Availability of PV plant is as important as peak capacity
- Kogarah availability was low
- Presently availability is not rewarded in \$ (1 week ~ \$7)
- PVRP is a payment based on potential to generate
- Need to move to a delivered energy payment "feed in tariff"



UNSW } ENGINEERING

ANZSES 2006

System performance - temperature



- Irradiance and temperature main factors in PV power
- 4157 hours of data logged
- Tarray > 25°C 66% of time,
- Tarray > 50°C 23% of time,
- Tarray > 60°C 8% of time,
- Tarray > 70°C 0.4% of time,
- Tarray > NOCT (47) 29%


- High temps' = low voltage
- Tarray of Tamb+30 ~ to 4.8Vdrop per 72 cell module
- Inverter may "bottom out" or "flat line" on P-V curve
- Non optimum operation

UNSW } ENGINEERING

ANZSES 2006



System performance - temperature




UNSW } ENGINEERING

ANZSES 2006



System performance – PR



- PR quantifies the overall effect of losses on the rated output
- Effect of temperature clearly visible as is the lower daily insolation of June compared to December.
- For Dec. & Jun average daily PR is 70% - indicates good overall system performance
- Daily max of 74% in Dec. and 78% in June.

UNSW } ENGINEERING

ANZSES 2006



Case Study

NSW
Department
of Planning
Newington
Solar Village

UNSW } ENGINEERING

ANZSES 2006



Newington Solar Village

- 780 homes with 1000Wp of PV and 199 houses with 500Wp
- Passive solar design features, energy efficient appliances
 - Loads nevertheless av 16 kWh/day cf 7.5 design
 - Load profile much 'peakier' than for normal houses, thus providing less opportunity for PV to reduce peak
- 30 homes monitored July 04-June 05
 - Average daily PV output per house 3.2 kWh (~20% of load)
 - 2 systems faulty -> 3.4 kWh/house, about 10% lower than expected (although 2005 may not have been a typical year)
 - Zone substation peak demand reduced by 30% of rated PV capacity


UNSW ENGINEERING

ANZSES 2006



Household Load and PV Output

average over 30 houses
(NSW Dept of Planning, Newington study)




UNSW ENGINEERING

ANZSES 2006



Annual Average Daily PV Output, Household Load and Offset, Newington




UNSW ENGINEERING


ANZSES 2006




PV Output, Household Load and Temperature - Peak Summer Day, Newington




PV Output, Household Load and Temperature - Peak Winter Day, Newington




Annual Average PV Output (X10) and Homebush Bay Substation Load



PV Output, Homebush Bay Substation Load and Temperature - Peak Load Summer Day



Load Duration Curve Homebush Bay with impact of 10X current PV Output



Conflicting expectations and objectives

- Buy back rates 4 to 14 c/kWh and minimal (zero!) reward to PV systems for daytime contribution
- Net metered systems - owner encouraged to maximise PV output
- No incentive to maximise grid benefits.
 - North West - 4% reduction in owner's income
 - West - 13% reduction
- Newington - reduction in substation peak load due to PV
- Split benefits, no carbon price
 - Difficult to argue in favour of grid-connected PV
- Electricity retailers moving away from net metering in sharp contrast to international trends to high feed-in tariffs for PV, now adopted in 41 jurisdictions

System performance and customer expectations

- Failure of system equipment, especially if undetected, contribute to customer expectations not being met.
- More common - system operating, but not at optimum.
 - Owner often unaware, especially if inverter in poor location and no remote display is available.
 - Net metering and a lack of weather data can contribute to ignorance.
- Knowledge of module voltage and temperature can be used to ascertain whether system is operating at maximum power point
- System owners could be provided with a simple table showing PV output range expected at various temperatures
 - If output falls outside range, a simple maintenance checklist could be used, with a maintenance call as the final option.
- Without some indicator of system output, however, even this simple check cannot be undertaken.

Conclusions

- Grid-connected PV market just beginning in Australia.
- Over 6 MW now installed, but potential market very large,
- With a minimal level of system checking, it is possible to ensure high system availability and good performance ratios.
- High temperatures in Australia indicate a need to ensure appropriate system design, wiring and component placement.
- PV systems reported here each displace 1.3 - 1.6 tonnes of CO₂ per kWp per year and could be expected to do so for 30 years or more.
- Increased uptake of grid-connected PV could play a useful role in reducing Australia's greenhouse gas emissions.
- Alternative support structures, which provide more incentive to maintain high output and reduce greenhouse gas emissions would assist in future market development.

Recommendations (1)

- Meeting customer expectations is critically important if this market is to meet its potential.
- Customers need clear and easy-to-understand information which explains key aspects of system design and expected performance.
 - maintenance checklists,
 - expected output at different temperatures
 - significance of aspects such as shading, dust build-up, loose connections and inverter over-heating.
- Discussion and explanation needed, not just a manual.
 - Video/DVD based information
 - Displays
- Establishment of a PV owners' networks, email or telephone-based help lines.

Recommendations (2)

- Mandatory net metering as minimum buy-back rate
- High buy-back rates or 'feed-in-tariffs'
 - encourage optimum system operation
 - encourage maintenance contracts and longer warranties
 - reduces up-front costs, since these are not subsidised
 - more cost effective means of technology support than more generic mechanisms such as MRET
 - no need for annual budget allocations
 - tariff can be adjusted as prices change and can also be varied by location, for instance, to encourage PV in grid-constrained areas