

Impacts of Operational Constraints on Generation Portfolio Planning with Variable Renewable Generation

Peerapat Vithayasrichareon (peerapat@unsw.edu.au), Thomas Lozanov, Jenny Riesz and Iain MacGill
Centre for Energy and Environmental Markets and School of Electrical Engineering and Telecommunications
UNSW Australia, Sydney, Australia


1. Context

- ◆ Wind and solar are now achieving high penetrations in power systems.
- ◆ Concerns over the operational and economic impacts of renewables on power systems due to their variability and partly dispatchable nature.
- ◆ Variable renewable generation poses operational challenges for conventional generating plants in terms of frequent cycling operation and may increase overall costs.
- ◆ *Load Duration Curve (LDC) techniques often used in generation planning - simple but ignore inter-temporal operational aspects.*
- ◆ Optimal generation portfolios obtained under long-term planning models may not be operationally viable or economically optimal in practice.
- ◆ Long-term generation planning models need to capture plant operational characteristics and their ability to respond to changes in demand to ensure that power systems can accommodate high renewables (e.g. *minimum operating levels, ramp rates, startup times & costs*).

4. Australian NEM Case Study


- ◆ Six different renewable penetration scenarios in 2030.
- ◆ Main generation technology options are coal, CCGT, OCGT, hydro, wind (on shore), utility scale PV (single axis tracking).
- ◆ Three carbon price scenarios: low, moderate and high.

Typical weekly generation patterns for portfolios with 40% and 75% renewable penetration




Thermal plants are required to cycle more often with higher RE penetrations

Detailed operational dispatch - Number of starts/stops




- ◆ Number of unit starts/stops depend on RE penetration levels and the technology share in the portfolio.
- * *The highest no. of starts for CCGT is 230/unit/year - within design range.*
- * *Number of coal starts seem technically viable for most portfolios. For high renewables, coal units might experience up to 100 starts/year.*
- ◆ Also depends on the carbon price.

Projected hourly demand and PV and generation in 2030



Load Duration Curve (LDC)



2. Objectives

- ◆ To assess how generator operational characteristics might impact future generation portfolios with high renewables obtained under long-term generation portfolio planning models.
- ◆ Technical and cost impact of the operational constraints.
- ◆ Compare the overall costs obtained from a long-term planning model with those from solving a detailed inter-temporal constrained dispatch.

3. Methodology

RE penetration scenario in 2030




- ◆ Using a long-term portfolio planning tool, **MC-ELECT**, to obtain optimal portfolios for different renewable penetrations for 2030.
 - ◆ Detailed modelling of future uncertainties but uses LDC which ignores short term operation aspect and constraints.
- ◆ Using **PLEXOS** (a commercial power market modelling tool) to solve a detailed inter-temporal constrained dispatch based on SRMC.
 - ◆ The least cost portfolios from MC-ELECT are rerun through a year of hourly constrained dispatch in PLEXOS.
 - ◆ Constraints included are *minimum generation levels, ramp rates, synchronous generation requirements and startup costs.*
 - ◆ *Synchronous generation* is provided by conventional generators to provide adequate system inertia.
 - ◆ Costs can then be compared to assess the impact of constraints.

Impact of minimum generation and ramp rate limits

- ◆ Min. generation and ramp rate constraints only slightly increase the overall costs of portfolios obtained under the long-term planning.
- ◆ All of the portfolios can meet the maximum ramps required even with high RE.

RE	Portfolios	Total generation cost (\$/MWh)			% Cost increase	
		Without constraints	With Min. gen	Min. gen & ramp rates	With Min. gen	Min. gen & ramp rates
30%	36% coal, 12% CCGT, 12% OCGT	108.0	108.0	108.0	0	0
	18% coal, 42% CCGT, 0% OCGT	119.1	119.1	119.1	0	0
40%	10% coal, 40% CCGT, 0% OCGT	115.2	115.3	115.3	0.1%	0.1%
	10% coal, 40% CCGT, 0% OCGT	104.2	104.3	104.3	0.1%	0.1%
60%	24% coal, 4% CCGT, 12% OCGT	97.1	97.8	97.8	0.1%	0.1%
	12% coal, 28% CCGT, 0% OCGT	104.9	105.6	105.6	0.7%	0.7%
85%	16% coal, 3% CCGT, 8% OCGT	100.3	102.3	102.4	2%	2%
	5% coal, 16% CCGT, 5% OCGT	105.5	106.5	106.5	1%	1%

Impact of synchronous generation requirement



- ◆ Synchronous requirements impose significant additional costs at high RE penetrations (~7% cost increase)
- * *Low operating cost renewables are curtailed to accommodate thermal generation*
- ◆ Negligible impact at low penetrations
- ◆ Costs associated with synchronous requirement increase with higher carbon prices

5. Conclusions

- ◆ Technical and cost impacts due to the inclusion of minimum generation and ramp rate constraints seem moderate even at high RE penetrations.
- ◆ Frequent cycling operation for coal and CCGT units as RE penetration increases, but generally appears within technical limits.
- ◆ The synchronous requirements can have significant cost impact.
- ◆ The impacts also depend on carbon price and the generation mix.
- ◆ Future work will explore issues at finer dispatch time intervals.

Acknowledgements: This work has been supported by the Australian Renewable Energy Agency (ARENA) and the Commonwealth Scientific and Industrial Research Organisation (CSIRO)